

इंटरनेट

मानक

Disclosure to Promote the Right To Information

Whereas the Parliament of India has set out to provide a practical regime of right to information for citizens to secure access to information under the control of public authorities, in order to promote transparency and accountability in the working of every public authority, and whereas the attached publication of the Bureau of Indian Standards is of particular interest to the public, particularly disadvantaged communities and those engaged in the pursuit of education and knowledge, the attached public safety standard is made available to promote the timely dissemination of this information in an accurate manner to the public.

“जानने का अधिकार, जीने का अधिकार”

Mazdoor Kisan Shakti Sangathan

“The Right to Information, The Right to Live”

“पुराने को छोड़ नये के तरफ”

Jawaharlal Nehru

“Step Out From the Old to the New”

IS 3957 (1966): Quality tolerances for water for ice manufacture [FAD 25: Drinking Water]



“ज्ञान से एक नये भारत का निर्माण”

Satyanarayan Gangaram Pitroda

“Invent a New India Using Knowledge”



“ज्ञान एक ऐसा खजाना है जो कभी चुराया नहीं जा सकता है”

Bhartrhari—Nitiśatakam

“Knowledge is such a treasure which cannot be stolen”

BLANK PAGE



IS : 3957 - 1966
(Reaffirmed 1983)

Indian Standard
**QUALITY TOLERANCES FOR
WATER FOR ICE MANUFACTURE**

(Third Reprint MARCH 1989)

UDC 663.61:621.58

**BUREAU OF INDIAN STANDARDS
MANAK BHAVAN, 9 BAHADUR SHAH ZAFAR MARG
NEW DELHI 110002**

Indian Standard

QUALITY TOLERANCES FOR WATER FOR ICE MANUFACTURE

Water Sectional Committee, CDC 26

Chairman

DR T. R. BHASKARAN

Representing

Indian Council of Medical Research, New Delhi

Members

SHRI K. L. BANERJEE	National Test House, Calcutta
SHRI N. C. SENGUPTA (Alternate)	
DR P. R. BAVDEKAR	Tata Chemicals Ltd, Bombay
DR R. P. DAROGA (Alternate)	
SHRI M. V. BOPARDIKAR	Central Public Health Engineering Research Institute (CSIR), Nagpur
CHEMIST & METALLURGIST, CENTRAL RAILWAY, BOMBAY SECTIONAL OFFICER (CM), CHITTARANJAN (Alternate)	Railway Board (Ministry of Railways)
DR I. C. DOS M. PAIS CUDDOU	Central Water & Power Commission, New Delhi
SHRI N. C. RAWAL (Alternate)	
SHRI R. R. DEO	The Paterson Engineering Co (India) Private Ltd, Calcutta
DR N. F. DESAI	Sandoz (India) Ltd, Bombay
DIRECTOR OF SCIENTIFIC RE- SEARCH (NAVY)	Naval Headquarters
SCIENTIFIC OFFICER (ICE) (Alternate)	
DR M. I. GURBAKANI	The Tata Iron & Steel Co Ltd, Jamshedpur
DR B. B. PAUL	All India Distillers' Association, New Delhi
SHRI N. N. MEHTA (Alternate)	
DR S. C. PILLAI	Indian Institute of Science, Bangalore
SHRI C. V. S. RATNAM	Neyveli Lignite Corporation Ltd, Neyveli
SHRI G. M. RAWAL	The Tata Hydro-Electric Power Supply Co Ltd, Bombay
SHRI R. K. BASU (Alternate)	
DR V. SADASIVAN	Bombay Municipal Corporation, Bombay
DR B. SARMA	Ministry of Defence (R & D)
SHRI V. K. RAIZADA (Alternate)	
SHRI B. A. SHOLAPURWALA	Italab Private Ltd, Bombay
SHRI V. M. SHAH (Alternate)	
SHRI B. C. SHOME	ICI (India) Private Ltd, Calcutta
DR R. MOUDGAL (Alternate)	
SHRI K. G. VEERARAGHAVAN	Director of Public Health, Government of Madras

(Continued on page 2)

BUREAU OF INDIAN STANDARDS
MANAK BHAVAN, 9 BAHADUR SHAH ZAFAR MARG
NEW DELHI 110002

IS : 3957 - 1966

(Continued from page 1)

Members

DR K. VENKATARAMANAN

SHRI M. R. VERMA

DR SADGOPAL,
Director (Chem)

Representing

Directorate General of Health Services (Ministry of Health)

National Physical Laboratory (CSIR), New Delhi
Director General, ISI (Ex-officio Member)

Secretary

DR G. M. SAXENA

Deputy Director (Chem), ISI

Water For Industrial Purposes Subcommittee, CDC 26 : 2

Convener

SHRI R. R. DEO

The Paterson Engineering Co (India) Pvt Ltd,
Calcutta

Members

SHRI K. R. BULURU

Central Public Health Engineering Research Institute
(CSIR), Nagpur

SHRI S. D. DANDEKAR

Cainlin Private Ltd, Bombay

DR N. F. DESAI

Sandoz (India) Ltd, Bombay

SHRI E. K. JAYANARAYANAN

Dyer Meakin Breweries Ltd, Solan

DR V. SADASIVAN

Bombay Municipal Corporation, Bombay

SHRI S. SAMPATH

Central Electrochemical Research Institute (CSIR)
Karaikudi

SHRI N. V. PARTHASARADHY (Alternate)

SHRI B. A. SHOLAPURWALA

Italab Private Ltd, Bombay

SHRI V. M. SHAH (Alternate)

SHRI M. R. SRINIVASAN

National Dairy Research Institute, Karnal

SHRI K. G. VEERARAGHAVAN

Director of Public Health, Government of Madras

AMENDMENT NO. 1 APRIL 1981

TO

IS:3957-1966 QUALITY TOLERANCES FOR WATER
FOR ICE MANUFACTURE

Addendum

[Page 4, Table 2, Sl. NO. (xxi)] - Add the following
new matter under respective columns after Sl No. (xxi):

(1)	(2)	(3)	(4)
xxii)	Cadmium (as Cd), mg/l, Max	0.01	See Note
xxiii)	Mercury (as Hg), mg/l, Max	0.001	See Note

NOTE - Methods of test for these characteristics are under preparation; till then methods of test as given in Standard Methods for the examination of water and wastewater. 1975. American Public Health Association; American Water Works Association; and Water Pollution Control Federation, USA, shall be followed.'

(CDC 26)

Reprography Unit, BIS, New Delhi, India

AMENDMENT NO. 2 NOVEMBER 2003
TO
IS 3957 : 1966 QUALITY TOLERANCES FOR WATER
FOR ICE MANUFACTURE

(*Page 3, clause 1.1*) — Substitute the following for the existing:

‘1.1 This standard prescribes the quality tolerances for water used in ice manufacture. It shall be of the following two grades:

Grade 1 Water for use for direct cooling

Grade 2 Water for use for indirect cooling’

(*Page 3, clause 2.1*) — Insert the following new clause and renumber the existing clause:

“2.1 Grade 1 —Quality tolerances for Grade 1 water for direct cooling shall be in accordance with requirements given in 3 of IS 10500 : 1991 ‘Drinking water (*first revision*)’.”

[*Page 3, clause 2.1 (renumbered clause 2.2, line 1)*] — Substitute ‘Quality tolerances for Grade 2 water for indirect cooling shall be as’ *for* ‘The water shall comply with the tolerances’.

(CHD 13)

Indian Standard

QUALITY TOLERANCES FOR WATER FOR ICE MANUFACTURE

0. FOREWORD

0.1 This Indian Standard was adopted by the Indian Standards Institution on 24 September 1966, after the draft finalized by the Water Sectional Committee had been approved by the Chemical Division Council.

0.2 Ice is manufactured in a number of food industries, in cold storage plants and exclusively in ice-making industry. Good quality ice should be clear, colourless, free from air bubbles, snowy butts and heavy cores. It should not shatter when handled. On melting, it should give a water of potable quality in its bacteriological, physical and chemical features. Hence the quality of water used in ice making is of utmost public health importance.

0.3 In preparing this standard, assistance has been obtained from the following publications:

United States of America. California State Water Pollution Control Board. McKee and Wolf. Water quality criteria. Ed 2 (Publication No. 3A). 1963. Sacramento.

Special Technical Publication 148-D. 1959. Manual on industrial water. Ed 2. American Society for Testing and Materials, USA.

0.4 For the purpose of deciding whether a particular requirement of this standard is complied with, the final value, observed or calculated, expressing the result of a test or analysis, shall be rounded off in accordance with IS : 2-1960*. The number of significant places retained in the rounded off value should be the same as that of the specified value in this standard.

1. SCOPE

1.1 This standard prescribes the quality tolerances for water used in ice manufacture.

2. TOLERANCES

2.1 The water shall comply with the tolerances given in Tables 1 to 3 for its bacteriological; physical and chemical; and radioactive characteristics when tested according to the methods given in IS : 1622-1964† and

*Rules for rounding off numerical values (revised).

†Methods of sampling and test for microbiological examination of water used in industry.

IS : 3025-1964*. Reference to the relevant clauses of these standards is given in col 4 of Table 1, Table 2 and Table 3.

TABLE 1 TOLERANCES FOR BACTERIOLOGICAL QUALITY

(Clause 2.1)

Sr No.	CHARACTERISTIC	TOLERANCE	METHOD of TEST (REF TO CL No. in IS : 1622- 1964*)
(1)	(2)	(3)	(4)
i)	Coliform bacteria, MPN index per 100 ml, <i>Max</i>	Less than 1	3.2
ii)	Standard plate count, per ml, <i>Max</i>	100	5

*Methods of sampling and test for microbiological examination of water used in industry.

TABLE 2 TOLERANCES FOR PHYSICAL AND CHEMICAL QUALITY

(Clause 2.1)

Sr No.	CHARACTERISTIC	TOLERANCE	METHOD OF TEST (REF TO CL No. in IS : 3025- 1964*)
(1)	(2)	(3)	(4)
i)	Colour (Hazen units), <i>Max</i>	5	5
ii)	Turbidity, units, <i>Max</i>	5	6
iii)	Odour	None	7
iv)	pH	6.5 to 9.2	8
v)	Total dissolved solids, mg/l, <i>Max</i>	1 000†	12
vi)	Alkalinity (as CaCO ₃), mg/l, <i>Max</i>	100	13
vii)	Total hardness (as CaCO ₃), mg/l, <i>Max</i>	600	16
viii)	Sulphate (as SO ₄), mg/l, <i>Max</i>	200	20
ix)	Fluoride (as F), mg/l, <i>Max</i>	1.5	23
x)	Chloride (as Cl), mg/l, <i>Max</i>	250	24
xi)	Cyanide (as CN), mg/l, <i>Max</i>	0.01	27
xii)	Selenium (as Se), mg/l, <i>Max</i>	0.05	28
xiii)	Iron (as Fe), mg/l, <i>Max</i>	0.3	32
xiv)	Magnesium (as Mg), mg/l, <i>Max</i>	125	34
xv)	Manganese (as Mn), mg/l, <i>Max</i>	0.2	35
xvi)	Copper (as Cu), mg/l, <i>Max</i>	1.0	36
xvii)	Lead (as Pb), mg/l, <i>Max</i>	0.1	37
xviii)	Chromium (as Cr ⁶⁺), mg/l, <i>Max</i>	0.05	38
xix)	Zinc (as Zn), mg/l, <i>Max</i>	15.0	39
xx)	Arsenic (as As), mg/l, <i>Max</i>	0.2	40
xxi)	Phenolic substances (as C ₆ H ₅ OH), mg/l, <i>Max</i>	0.001	54

*Methods of sampling and test (physical and chemical) for water used in industry.

†For clear, transparent ice, total dissolved solid content should not exceed 300 mg/l.

*Methods of sampling and test (physical and chemical) for water used in industry.

TABLE 3 TOLERANCES FOR RADIOACTIVITY

(Class 2.1)

Sl. No.	CHARACTERISTIC	TOLERANCE	METHOD OF TEST (REF TO CL No. IN IS : 3025-1964*)
(1)	(2)	(3)	(4)
i)	<i>Alpha</i> emitters, μ c/ml, <i>Max</i>	10^{-9}	58
ii)	<i>Beta</i> emitters, μ c/ml, <i>Max</i>	10^{-8}	

*Methods of sampling and test (physical and chemical) for water used in industry.

3. SAMPLING

3.1 Representative test samples of water shall be drawn as prescribed in 2 of IS : 1622-1964* and 2 of IS : 3025-1964†.

4. TEST METHODS

4.1 Tests shall be carried out as prescribed in the appropriate clauses, indicated against the characteristic in Table 1, Table 2 and Table 3. of IS : 1622-1964* and IS : 3025-1964†.

*Methods of sampling and test for microbiological examination of water used in industry.

†Methods of sampling and test (physical and chemical) for water used in industry.

BUREAU OF INDIAN STANDARDS

Headquarters :

Manak Bhavan, 9 Bahadur Shah Zafar Marg, NEW DELHI 110002

Telephones : 3 31 01 31, 3 31 13 75

Telegrams : Manaksanstha
(Common to all Offices)

Regional Offices :

Telephone

*Western ; Manakalaya, E9 MiDC, Marol, Andheri (East), 6 32 92 95
BOMBAY 400093

†Eastern : 1/14 C. I. T. Scheme VII M, V. I. P. Road, 36 24 99
Maniktola, CALCUTTA 700054

Northern : SCO 445-446, Sector 35-C { 2 18 43
CHANDIGARH 160036 { 3 16 41

Southern : C. I. T. Campus, MADRAS 600113 { 41 24 42
{ 41 25 19
{ 41 29 16

Branch Offices :

Pushpak, Nurmohamed Shaikh Marg, Khanpur, { 2 63 48
AHMADABAD 380001 { 2 63 49

'F' Block, Unity Bldg, Narasimharaja Square, 22 48 05
BANGALORE 560002

Gangotri Complex, 5th Floor, Bhadbhada Road, T. T. Nagar, 6 27 16
BHOPAL 462003

Plot No. 82/83, Lewis Road, BHUBANESHWAR 751002 5 36 27

53/5 Ward No. 29, R. G. Barua Road, —
5th Byelane, GUWAHATI 781003

5-8-56C L. N. Gupta Marg, (Nampally Station Road), 22 10 83
HYDERABAD 500001

R14 Yudhister Marg, C Scheme, JAIPUR 302005 { 6 34 71
{ 6 98 32

117/418B Sarvodaya Nagar, KANPUR 208005 { 21 68 76
{ 21 82 92

Patliputra Industrial Estate, PATNA 800013 6 23 05

Hantex Bldg (2nd Floor), Rly Station Road, 52 27
TRIVANDRUM 695001

Inspection Office (With Sale Point):

Institution of Engineers (India) Building, 1332 Shivaji Nagar, 5 24 35
PUNE 410005

*Sales Office in Bombay is at Novelty Chambers, Grant Road, 89 65 28
Bombay 400007

†Sales Office in Calcutta is at 5 Chowringhee Approach, P. O. Princep 27 68 00
Street, Calcutta 700072

Reprography Unit, BIS, New Delhi, India